



Borehole Yield and Quality Testing at Portion 63 of Farm 918, Strand, Western Cape.

REPORT:

GEOSS Report No: 2023/06-16


PREPARED FOR:

Heloïse Groenewald
GNEC Environmental Consultants
Email: hdp@gnec.co.za
&
Divan Opperman
GNEC Environmental Consultants
Email: divan@gnec.co.za

PREPARED BY:

Ashleigh Lakshuman
GEOSS South Africa (Pty) Ltd
Unit 12, Technostell Building,
9 Quantum Street,
Technopark
Stellenbosch 7600
Tel: (021) 880-1079
Email: info@geoss.co.za
(www.geoss.co.za)

23 June 2023



EXECUTIVE SUMMARY

GEOSS South Africa (Pty) Ltd was appointed by Heloïse Groenewald from GNEC Environmental Consultants to conduct a camera log, and yield and groundwater quality testing of two boreholes at Portion 63 of Farm 918, Strand, Western Cape. The boreholes were tested by ATS under the management and supervision of GEOSS from 30 May to 3 June 2023. This included a Step Test, CDT and Recovery Test at each borehole. It is recommended that groundwater abstraction can occur within the below-mentioned parameters from the tested boreholes. Aquifer over-abstraction is unlikely to occur if these rates are adhered to and if the boreholes are managed through long-term monitoring data.

Borehole Details				
Borehole Name	Latitude (DD)	Longitude (DD)	Borehole Depth (m)	Inner Diameter (mm)
HP_BH3	-34.11870	18.88440	114.2	160
HP_BH4	-34.11934	18.88464	36.2	110
Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
HP_BH3	0.2	24	0	17 280
HP_BH4	0.85	24	0	73 440
			TOTAL	90 720
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
HP_BH3	68	67	50	21.49
HP_BH4	33	32	21	19.45

* Typical water level expected during long-term production

Please note that HP_BH4 was not tested to its full capacity due to access to the borehole being limited as HP_BH4 is situated on a slope. This prevented the safe installation of larger testing equipment.

Through long-term water level monitoring data, the abstraction volumes can be optimised by adjusting the abstraction rate, if required. This can be achieved by means of a gate valve. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

From the laboratory results, the groundwater from HP_BH3 and HP_BH4 is of poor quality for potable supply. The total dissolved solids and electrical conductivity of both boreholes are elevated into the category of marginal. This is related to the elevated concentrations of sodium and chloride,

which exceed the aesthetic limits of the SANS 241-1:2015 drinking water guidelines. The turbidity of HP_BH3 is elevated to the category of marginal. This is related to the high concentration of iron in the borehole. Additionally, the iron, fluoride and manganese concentrations of HP_BH3 exceeds the chronic health limit of the SANS 241-1:2015 drinking water guidelines. Iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as the abstraction infrastructure. Additionally, HP_BH4 has an E.coli content in the groundwater that exceeds the acute health limit of the SANS 241-1:2015 drinking water guidelines. As such, groundwater from both of these boreholes should not be consumed prior to treatment.

To address the potential for iron to clog the borehole (HP_BH3) and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule as much as possible. Thus, should a daily volume of less than 17 280 L/d be required, it is recommended to decrease the pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimised decreasing the amount of iron precipitation inside the boreholes and pumps.

To facilitate monitoring and informed management of a borehole, it is recommended to equip boreholes with the following monitoring infrastructure and equipment:

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m.
- Installation of an electronic water level logger (for automated water level monitoring)
- Installation of a sampling tap (to monitor water quality)
- Installation of a flow volume meter (to monitor abstraction rates and volumes)

This report is an important document for obtaining legal compliance with regard to the use of groundwater with the Department of Water and Sanitation but does not constitute a Geohydrological Assessment report in support of a WULA, which would need to incorporate information from this report.

TABLE OF CONTENTS

1. INTRODUCTION	1
2. YIELD TESTING.....	1
2.1 Methodology.....	1
2.2 Yield Testing at HP_BH3.....	6
2.3 Yield Testing at HP_BH4.....	9
3. WATER QUALITY ANALYSIS	12
4. RECOMMENDATIONS.....	17
5. REFERENCES	19
6. APPENDIX A: ESTIMATED BOREHOLE LOG.....	20
7. APPENDIX B: CAMERA LOGGING	23
8. APPENDIX C: YIELD TEST DATA.....	27
9. APPENDIX D: WATER QUALITY.....	36
10. APPENDIX E: MONITORING INFRASTRUCTURE DIAGRAM.....	43
11. APPENDIX F : YIELD TEST DATA ANALYSIS	46

LIST OF FIGURES

Figure 1: (Left) HP_BH3 before testing, (Right) HP_BH4 during testing.	1
Figure 2: Borehole Locality Map	3
Figure 3: Geological Map with Property Boundary and Tested Borehole Positions (1:50 000 Geological Map Series, 3418BB Somerset West & 3418BD Hangklip)(CGS, 2019).....	4
Figure 4: Step Test drawdown data for HP_BH3.....	6
Figure 5: Semi-Log Plot of drawdown during the CDT of HP_BH3 (0.42 L/s).	7
Figure 6: Time-series drawdown and recovery for HP_BH3 (0.42 L/s).....	7
Figure 7: Step Test drawdown data for HP_BH3.....	9
Figure 8: Semi-Log Plot of drawdown during the CDT of HP_BH4 (0.86 L/s).	10
Figure 9: Time-series drawdown and recovery for HP_BH4 (0.86 L/s).....	10
Figure 10: Piper diagram of the groundwater sample.....	15
Figure 11: SAR diagram of the groundwater sample.....	16
Figure 12: Borehole testing set up a few meters away from the HP_BH4.	18

LIST OF TABLES

Table 1: Borehole Details	1
Table 2: Yield Determination - HP_BH3	8
Table 3: Yield Determination - HP_BH4	11
Table 4: Classification table for specific limits.....	12
Table 5: Classification table for the groundwater results (DWAF, 1998)	12
Table 6: Production boreholes' results classified according the SANS241-1:2015.....	13
Table 7: Classified production boreholes' results according to DWAF 1998.....	14
Table 8: Borehole Abstraction Recommendations	17

ABBREVIATIONS

AD	available drawdown
bh	borehole
CDT	constant discharge test
DWA	Department of Water Affairs (pre- 1994)
DWAF	Department of Water Affairs and Forestry (1994 – 2009)
DWS	Department of Water and Sanitation (2009 –)
ID	inner diameter
L/s	litres per second
L/d	litres per day
m ² /d	meters squared per day
m	metres
mbgl	metres below ground level
RWL	rest water level below ground level
T	Transmissivity

GLOSSARY OF TERMS

Aquifer: a geological formation, which has structures or textures that hold water or permit appreciable water movement through them [from National Water Act (Act No. 36 of 1998)].

Available drawdown: Available drawdown in a borehole is the difference between the rest water level or piezometric surface and the depth that the water level may drop to (typically major water bearing unit, boundary inflection or pump depth).

Dynamic water level: the stabilised water level in the borehole during production over long periods of time.

Groundwater: water found in the subsurface in the saturated zone below the water table or piezometric surface i.e., the water table marks the upper surface of groundwater systems.

Rest water level: The groundwater level in a borehole not influenced by abstraction or artificial recharge.

Sustainable yield: Sustainable yield is defined as the rate of withdrawal that can be sustained by an aquifer without causing an unacceptable decline in the hydraulic head or deterioration in water quality in the aquifer.

Transmissivity: The rate at which water is transmitted through a unit width of an aquifer under a unit hydraulic gradient.

Suggested citation for this report:

GEOSS (2023). Borehole Yield and Quality Testing at Portion 63 of Farm 918, Strand, Western Cape. Report Number: 2023/09-16. GEOSS South Africa (Pty) Ltd. Stellenbosch, South Africa.

Cover photo:

Rig set up at HP_BH3

GEOSS project number:

2021_07–4450 Phase G

Reviewed by:

Reuben Lazarus (22 June 2023) & Dale Barrow (23 June 2023)

1. INTRODUCTION

GEOSS South Africa (Pty) Ltd was appointed by Heloïse Groenewald from GNEC Environmental Consultants to conduct a camera log, and yield and water quality testing of two boreholes at Portion 63 of Farm 918, Strand, Western Cape. The boreholes that were tested are displayed in **Figure 1**.

The boreholes were tested by ATS under the management and supervision of GEOSS from 30 May to 3 June 2023, details of this are presented in this report. The boreholes' details are presented in **Table 1** below and spatially in **Figure 2**. No drilling logs were made available, however; estimations of the boreholes' construction are presented in **Appendix A**. Camera logs of both boreholes were conducted to determine the construction of the boreholes and these are presented in **Appendix B**. The geological setting of the area and the camera logging suggests that HP_BH3 is drilled into the fractured shales of the Tygerberg Formation (EDt) and HP_BH4 is drilled into the overlying alluvium (**Figure 3**).

Table 1: Borehole Details

Borehole	Latitude (DD-WGS84)	Longitude (DD-WGS84)	Depth (m)
HP_BH3	-34.118704°	18.884398°	114.2
HP_BH4	-33.119343°	18.884644°	36.15



Figure 1: (Left) HP_BH3 before testing, (Right) HP_BH4 during testing.

2. YIELD TESTING

2.1 Methodology

The yield testing was undertaken by ATS under the management and supervision of GEOSS from 30 May to 3 June 2023 and carried out according to the National Standard (SANS 10299-4:2003, Part 4 – Test pumping of water boreholes). This included a Step Test, Constant Discharge Test and recovery monitoring of the borehole. For the Step Test, a borehole is pumped at a constant rate for one-hour intervals and the flow rates are incrementally increased for each step. This test is followed by a Constant Discharge Test (CDT) where the borehole is pumped at a constant rate for an extended period of time, followed by recovery monitoring. The water level drawdown is monitored at pre-determined intervals during these tests (drawdown refers to the difference in

water level from the rest water level (RWL) measured before the commencement of the yield test). Raw data and measurements taken during the yield tests are presented in **Appendix C**.



Figure 2: Borehole Locality Map




Figure 3: Geological Map with Property Boundary and Tested Borehole Positions (1:50 000 Geological Map Series, 3418BB Somerset West & 3418BD Hangklip)(CGS, 2019).

The yield test data was analysed using the excel-based FC program, developed by the IGS (Institute for Groundwater Studies) in Bloemfontein. The sustainable yield of the borehole was calculated based upon long-term extrapolations of the CDT data according to (1) the Cooper-Jacob approximation of the Theis solution for confined aquifers, (2) the Barker Generalised Radial Flow Model (GRF) for hydraulic tests in fractured rock and (3) the Flow Characteristic (FC) method(s) using first and second derivative calculations. Boundary conditions are accounted for in multiplication factors to the rate of drawdown (derivatives), according to each of the above three methods. These three methods are briefly described below.

1. The Cooper-Jacob approximation of the Theis solution for confined aquifers was designed for porous media aquifers, where infinite acting radial flow (IARF) was observed during the pumping of a borehole. The application of this method to fractured aquifers was discussed by Meier et al (1998), concluding that T estimates using the Cooper-Jacob analysis gave an effective T for the fracture zone. The Cooper-Jacob analysis (and more accurately the Theis method) is therefore viable for analysing pumping test data for fractured aquifers where IARF is observed. The parameters are then used to predict theoretical long-term drawdowns.
2. The Barker GRF Model (Barker, 1988) uses fracture hydraulic conductivity, fracture storativity and flow domain to predict drawdown due to abstraction in a borehole in a fractured medium. By changing these values, a curve of drawdown predictions can be made to fit real-world data and therefore predict theoretical long-term drawdowns.
3. The FC methods are the Basic FC, the FC Inflection Point and the FC Non-Linear. The Basic FC and the FC Inflection Point methods make use of the derivatives of the drawdown data to predict theoretical long-term drawdowns and the scale-back factors are applied to selected available drawdowns. The FC Non-Linear method uses curve fitting of the Step Test data to predict theoretical long-term drawdowns. Due to the short nature of the Step Test, this method is usually not included if the other methods of analysis differ from it.


In all three methods, the available drawdown was carefully selected to ensure that the flow regime described by the analytical solution is not extrapolated beyond its applicable depth, which may easily result in an overuse of the resource. For HP_BH3 this was 48 m, based on an inflection point observed during the step test. For HP_BH4 this was 13 m, based on the maximum pump installation depth. A two-year extrapolation time without recharge to the aquifer was selected as per the recommendations within the FC method program.

Water samples were collected at the end of the yield test and submitted for inorganic chemical and microbial analyses.

2.2 Yield Testing at HP_BH3

The yield testing was conducted between the 30th of May and 1st of June 2023. The borehole was measured to a depth of 114.2 meters below ground level (mbgl). The test pump was installed at a depth of 99.2 mbgl. The rest water level (RWL) at the start of the test was 21.49 mbgl.

During the step test, the water level was drawn down to pump inlet at the end of the 3rd step at a rate of 1.03 L/s (3 708 L/hour). **Figure 4** shows the time-series drawdown for the Step Test.






Figure 5: Semi-Log Plot of drawdown during the CDT of HP_BH3 (0.42 L/s).

The recovery of the water level was monitored after the 24-hour CDT and is presented in **Figure 6**. The recovery was very fast, reaching 96.1% in 2 hours.




Figure 6: Time-series drawdown and recovery for HP_BH3 (0.42 L/s).

Several methods were used to assess the yield test data as presented in **Table 2**. It is recommended that the borehole can be abstracted from at a rate of up to 0.2 L/s (720 L/hour) for 24 hours per day. The assessments were based on an available drawdown (AD) of 48 meters below the RWL of the CDT, 69.5 mbgl.

Table 2: Yield Determination - HP_BH3

HP_BH3			
Method	Sustainable Yield (L/s)	Late *T (m ² /d)	*AD used (m)
Basic FC	0.22	1.3	48.0
Cooper-Jacob	0.18	1.6	48.0
FC Non-Linear	0.20	1	48.0
Barker	0.19		48.0
Average Q_{sust} (L/s)	0.20		
Recommended Abstraction			
Abstraction Rate (L/s)	Abstraction Duration (hours)	Recovery Duration (hours)	
0.2	24	0	

*AD- Available Drawdown

*T – Transmissivity

2.3 Yield Testing at HP_BH4

The yield testing was conducted between the 1st and 3rd of June 2023. The borehole was measured to a depth of 36.15 meters below ground level (mbgl). Due to the limited access to the borehole, the largest pump that could be installed for testing was limited to a flow rate of 0.9 L/s. The test pump was installed at a depth of 33 mbgl. The rest water level (RWL) at the start of the test was 19.45 mbgl.

During the step test, the water level was drawn down 0.2 meters (19.65 mbgl) at the end of the 4th step at a rate of 0.9 L/s (3 240 L/hour). **Figure 7** shows the time-series drawdown for the Step Test.




Figure 7: Step Test drawdown data for HP_BH3.

The water level was left to recover overnight before starting the CDT. The water level at the start of the CDT was 19.45 mbgl. Based on the results of the Step Test, the planned 24-hour CDT was conducted at a rate of 0.86 L/s (3 096 L/hour). At the end of the 24-hour period, the water level had drawn down 0.29 meters below the rest water level (19.74 mbgl).

The semi-log plot of the drawdown from the CDT is presented in **Figure 8**.




Figure 8: Semi-Log Plot of drawdown during the CDT of HP_BH4 (0.86 L/s).

The recovery of the water level was monitored after the 24-hour CDT and is presented in **Figure 9**. The recovery was fast, reaching 96.6 % after 20 minutes.




Figure 9: Time-series drawdown and recovery for HP_BH4 (0.86 L/s).

Several methods were used to assess the yield test data as presented in **Table 3**. It is recommended that the borehole can be abstracted from at a rate of up to 0.85 L/s (3 060 L/hour) for 24 hours per day. The assessments were based on an available drawdown (AD) of 13 meters below the RWL of the CDT, 32.5 mbgl.

Table 3: Yield Determination - HP_BH4

HP_BH4			
Method	Sustainable Yield (L/s)	Late *T (m ² /d)	*AD used (m)
Basic FC	2.35	54.6	13.0
Cooper-Jacob	2.38	43.8	13.0
FC Non-Linear	1.43	156	13.0
Barker	1.78		13.0
Average Q_{sust} (L/s)	1.98		
Recommended Abstraction			
Abstraction Rate (L/s)	Abstraction Duration (hours)	Recovery Duration (hours)	
0.85	24	0	

*AD- Available Drawdown

*T – Transmissivity

3. WATER QUALITY ANALYSIS

Groundwater samples were collected from the boreholes at the end of the yield tests and submitted for inorganic chemical and microbial analyses to a SANAS accredited laboratory (Vinlab) in the Western Cape. The certificate of analysis for the samples are presented in **Appendix D**. The chemistry results obtained for the boreholes have been classified according to the SANS241-1: 2015 standards for domestic water (**Table 4**). **Table 6** presents the water chemistry analysis results, colour coded according to the SANS241-1: 2015 drinking water assessment standards.

Table 4: Classification table for specific limits

Acute Health	Chronic Health	Aesthetic	Operational	Acceptable
---------------------	-----------------------	------------------	--------------------	-------------------

The limits and associated risks for domestic water as determined by the South African National Standard (SANS) 241:2015 are as follows, where:

- Health risks: parameters falling outside these limits may cause acute or chronic health problems in individuals.
- Aesthetic risks: parameters falling outside these limits indicate that water is visually, aromatically or palatably unacceptable.
- Operational risks: parameters falling outside these limits may indicate that operational procedures to ensure water quality standards are met may have failed.

The chemistry results obtained have been classified according to the DWAF (1998) standards for domestic water. **Table 5** enables an evaluation of the water quality with regards to the various parameters measured (DWAF, 1998). **Table 7** presents the water chemistry analysis results colour coded according to the DWAF drinking water assessment standards.

Table 5: Classification table for the groundwater results (DWAF, 1998)

Blue	(Class 0)	Ideal water quality - suitable for lifetime use.
Green	(Class I)	Good water quality - suitable for use, rare instances of negative effects.
Yellow	(Class II)	Marginal water quality - conditionally acceptable. Negative effects may occur.
Red	(Class III)	Poor water quality - unsuitable for use without treatment. Chronic effects may occur.
Purple	(Class IV)	Dangerous water quality - totally unsuitable for use. Acute effects may occur.

Table 6: Production boreholes' results classified according the SANS241-1:2015

Analyses	HP_BH3	HP_BH4	SANS 241-1:2015
Date and Time Sampled	01/06/2023 07:50	03/06/2023 07:30	
pH (at 25 °C)	6.7	6.0	5.0 ≤ Operational ≤ 9.7
Conductivity (mS/m) (at 25 °C)	181.6	208.0	Aesthetic ≤170
Total Dissolved Solids (mg/L)	1231.25	1410.24	Aesthetic ≤1200
Turbidity (NTU)	125.0	1.58	Operational ≤1 Aesthetic ≤5
Colour (mg/L as Pt)	21.0	<15	Aesthetic ≤15
Sodium (mg/L as Na)	259	255	Aesthetic ≤200
Potassium (mg/L as K)	7	7	N/A
Magnesium (mg/L as Mg)	33	66	N/A
Calcium (mg/L as Ca)	43	30	N/A
Chloride (mg/L as Cl)	503.21	589.93	Aesthetic ≤300
Sulphate (mg/L as SO ₄)	30.33	61.43	Aesthetic ≤250 Acute ≤500
Nitrate & Nitrite Nitrogen (as a ratio)	0.10	0.26	≤1 Acute Health
Nitrate Nitrogen (mg/L as N)	<1.0	2.46	Acute Health ≤11
Nitrite Nitrogen (mg/L as N)	<0.05	<0.05	Acute Health ≤0.9
Ammonia Nitrogen (mg/L as N)	<0.15	<0.15	Aesthetic ≤1.5
Total Alkalinity (mg/L as CaCO ₃)	78.8	38.1	N/A
Total Hardness (mg/L as CaCO ₃)	242.8	345.6	N/A
Fluoride (mg/L as F)	3.5	0.36	Chronic Health ≤1.5
Aluminium (mg/L as Al)	0.416	0.07	Operational ≤0.3
Total Chromium (mg/L as Cr)	0.006	0.004	Chronic Health ≤0.05
Manganese (mg/L as Mn)	0.51	0.012	Aesthetic ≤0.1 Chronic ≤0.4
Iron (mg/L as Fe)	11.885	0.052	Aesthetic ≤0.3 Chronic ≤2
Nickel (mg/L as Ni)	<0.008	<0.008	Chronic Health ≤0.07
Copper (mg/L as Cu)	0.002	0.004	Chronic Health ≤2
Zinc (mg/L as Zn)	0.116	0.009	Aesthetic ≤5
Arsenic (mg/L as As)	<0.01	<0.01	Chronic Health ≤0.01
Selenium (mg/L as Se)	<0.008	<0.008	Chronic Health ≤0.04
Cadmium (mg/L as Cd)	0.003	0.002	Chronic Health ≤0.003
Antimony (mg/L as Sb)	<0.013	<0.013	Chronic Health ≤0.02
Mercury (mg/L as Hg)	<0.001	<0.001	Chronic Health ≤0.006
Lead (mg/L as Pb)	<0.008	<0.008	Chronic Health ≤0.01
Uranium (mg/L as U)	<0.028	<0.028	Chronic Health ≤0.03
Cyanide (mg/L as CN ⁻)	<0.01	<0.01	Acute Health ≤0.2
Total Organic Carbon (mg/L as C)	1.3	1.35	N/A
E.coli (count per 100 ml)	nd	1	Not Det. Acute Health-1
Total Coliform Bacteria (count per 100 ml)	nd	3	Not Det. ≤10 Operational
Heterotrophic Plate Count (count per ml)	nd	400	≤1000 Operational
Charge Balance Error %	1.1	-1.3	≥-5 - ≤5 Acceptable

Table 7: Classified production boreholes' results according to DWAF 1998.

	HP_BH3	HP_BH4	DWA (1998) Drinking Water Assessment Guide				
			Class 0	Class I	Class II	Class III	Class IV
			Ideal	Good	Marginal	Poor	Dangerous
Date and Time Sampled	01/06/2023 07:50	03/06/2023 07:30					
pH	6.7	6.0	5-9.5	4.5-5 & 9.5-10	4-4.5 & 10-10.5	3-4 & 10.5-11	< 3 & >11
Conductivity (mS/m)	181.6	208.0	<70	70-150	150-370	370-520	>520
Turbidity (NTU)	125.0	1.58	<0.1	0.1-1	1.0-20	20-50	>50
	mg/L						
Total Dissolved Solids	1231.25	1410.24	<450	450-1000	1000-2400	2400-3400	>3400
Sodium (as Na)	259	255	<100	100-200	200-400	400-1000	>1000
Potassium (as K)	7	7	<25	25-50	50-100	100-500	>500
Magnesium (as Mg)	33	66	<70	70-100	100-200	200-400	>400
Calcium (as Ca)	43	30	<80	80-150	150-300	>300	
Chloride (as Cl)	503.21	589.93	<100	100-200	200-600	600-1200	>1200
Sulphate (as SO ₄)	30.33	61.43	<200	200-400	400-600	600-1000	>1000
Nitrate & Nitrite (as a ratio)	0.1	0.26	<6	6.0-10	10.0-20	20-40	>40
Fluoride (as F)	3.50	0.36	<0.7	0.7-1.0	1.0-1.5	1.5-3.5	>3.5
Manganese (as Mn)	0.51	0.012	<0.1	0.1-0.4	0.4-4	4.0-10.0	>10
Iron (as Fe)	11.885	0.052	<0.5	0.5-1.0	1.0-5.0	5.0-10.0	>10
Copper (as Cu)	0.002	0.004	<1	1-1.3	1.3-2	2.0-15	>15
Zinc (as Zn)	0.116	0.009	<20	>20			
Arsenic (as As)	<0.01	<0.01	<0.010	0.01-0.05	0.05-0.2	0.2-2.0	>2.0
Cadmium (as Cd)	0.003	0.002	<0.003	0.003-0.005	0.005-0.020	0.020-0.050	>0.050
Hardness (as CaCO ₃)	242.800	345.6	<200	200-300	300-600	>600	
	counts/100 mL						
Faecal coliforms	nd	1	0	0-1	1.0-10	10-100	>100
Total coliforms	nd	3	0	0-10	10-100	100-1000	>1000
Charge Balance Error %	1.1	-1.3	≥-5 - ≤5 Acceptable				

From the chemical results presented in **Table 6** and **Table 7**, the groundwater from HP_BH3 and HP_BH4 is of poor quality for potable supply. The total dissolved solids and electrical conductivity of both boreholes are elevated into the category of marginal. This is related to the elevated concentrations of sodium and chloride, which exceed the aesthetic limits of the SANS 241-1:2015 drinking water guidelines. The turbidity of HP_BH3 is elevated to the category of marginal. This is related to the high concentration of iron in the borehole. Additionally, the iron, fluoride and manganese concentrations of HP_BH3 exceeds the chronic health limit of the SANS 241-1:2015 drinking water guidelines. Iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as the abstraction infrastructure. Additionally, HP_BH4 has an E.coli content in the groundwater that exceeds the acute health limit of the SANS 241-1:2015 drinking water guidelines. As such, groundwater from both of these boreholes should not be consumed prior to treatment.

A number of chemical diagrams have been plotted for the groundwater sample and these are useful for chemical characterisation of the water and illustrates the similarities and differences in the water types. The chemistry of the samples has been plotted on a tri-linear diagram known as a Piper diagram. This diagram indicates the distribution of cations and anions in separate triangles and then a combination of the chemistry in the central diamond. From **Figure 10**, (central diamond) the tested borehole groundwater samples are similar and are classified as a Sodium & Potassium/Chloride hydrofacies, typical of the Tygerberg formation that form the bedrock in the area.




Figure 10: Piper diagram of the groundwater sample.

The Sodium Adsorption Ratio (SAR) of the groundwater is plotted in **Figure 11**. HP_BH3 and HP_BH4 are both plotted as S2/C3, thus classified as medium risk in terms of sodium adsorption and high risk in terms of salinity hazard. This graph is typically applicable to irrigation, however is dependent on soil texture and crop type.




Figure 11: SAR diagram of the groundwater sample.

4. RECOMMENDATIONS

Based on the information obtained from the yield tests, the abstraction recommendations for the boreholes are presented in **Table 8**. The yield testing was conducted with a Step Test, Constant Discharge Test and Recovery Test and while this data can be analysed to estimate sustainable yields, additional drilling in the area may result in long term cumulative impacts. Optimisation of the resource is also possible through making small changes to the abstraction rates and duration, should the dynamic water level's drawdown be less or more than expected as per **Table 8**. Both of these points are best managed through long term monitoring data.

Table 8: Borehole Abstraction Recommendations

Borehole Details				
Borehole Name	Latitude (DD)	Longitude (DD)	Borehole Depth (m)	Inner Diameter (mm)
HP_BH3	-34.11870	18.88440	114.2	160
HP_BH4	-34.11934	18.88464	36.2	110
Abstraction Recommendations				
Borehole Name	Abstraction rate (L/s)	Abstraction Duration (hrs)	Recovery Duration (hrs)	Possible Volume Abstracted (L/d)
HP_BH3	0.2	24	0	17 280
HP_BH4	0.85	24	0	73 440
			TOTAL	90 720
Pump Installation Details				
Borehole Name	Pump Installation Depth (mbgl)	Critical Water Level (mbgl)	Dynamic Water Level (mbgl)*	Rest Water Level (mbgl)
HP_BH3	68	67	50	21.49
HP_BH4	33	32	21	19.45

* Typical water level expected during long-term production

For borehole HP_BH3 it is recommended that abstraction can occur at a rate of up to 0.2 L/s for up to 24 hours per day. A pump suitable to deliver the recommended rate should be installed at a depth of 68 mbgl. It is anticipated that abstraction at the recommended rate will cause the water level to drop to a depth of approximately 50 mbgl – this is referred to as the dynamic water level. During abstraction, a maximum level cut off switch should be installed to 67 mbgl to ensure the groundwater level does not drop to the pump inlet.

For borehole HP_BH4 it is recommended that abstraction can occur at a rate of up to 0.85 L/s for up to 24 hours per day. A pump suitable to deliver the recommended rate should be installed at a depth of 33 mbgl. It is anticipated that abstraction at the recommended rate will cause the water level to drop to a depth of approximately 21 mbgl – this is referred to as the dynamic water

level. During abstraction, a maximum level cut off switch should be installed to 32 mbgl to ensure the groundwater level does not drop to the pump inlet.

Please note that HP_BH4 was not tested to its full capacity due to access to the borehole being limited as HP_BH4 is situated on a slope and in cased in a brick block, refer to **Figure 12**. This prevented the safe installation of larger testing equipment. It is assumed that the borehole could deliver a larger volume, should the area around the borehole be levelled out to allow access to the borehole.



Figure 12: Borehole testing set up a few meters away from the HP_BH4.

From the laboratory results, the groundwater from HP_BH3 and HP_BH4 is of poor quality for potable supply. The total dissolved solids and electrical conductivity of both boreholes are elevated into the category of marginal. This is related to the elevated concentrations of sodium and chloride, which exceed the aesthetic limits of the SANS 241-1:2015 drinking water guidelines. The turbidity of HP_BH3 is elevated to the category of marginal. This is related to the high concentration of iron in the borehole. Additionally, the iron, fluoride and manganese concentrations of HP_BH3 exceeds the chronic health limit of the SANS 241-1:2015 drinking water guidelines. Iron biofouling is likely to occur in the borehole if the borehole is not managed optimally. This will result in the clogging of the borehole as well as the abstraction infrastructure. Additionally, HP_BH4 has an E.coli content in the groundwater that exceeds the acute health limit of the SANS 241-1:2015 drinking water guidelines. As such, groundwater from both of these boreholes should not be consumed prior to treatment.

To address the potential for iron to clog the borehole (HP_BH3) and abstraction infrastructure, it is recommended to maintain a constant and continuous pumping schedule. Thus, should a daily volume of less than 17 280 L/d be required, it is recommended to decrease the pumping rate and not the pumping duration. By pumping continuously instead of on a stop-start schedule, iron oxidation in the borehole is minimised, decreasing the amount of iron precipitation inside the boreholes and pumps.

Through long-term water level monitoring data, the abstraction volumes can be optimised by adjusting the abstraction rate, if required. It is recommended that the boreholes are equipped with gate valves. This enables adjustments to the flow rate to be made if required, as determined by the hydrogeological analysis of water level and flow rate monitoring data.

As of January 2018 the Department of Water and Sanitation released a Government Gazette stating that: “All water use sector groups and individuals taking water from any water resource (surface or groundwater) regardless of the authorization type, in the Berg, Olifants and Breede Gouritz Water Management Area, shall install electronic water recording, monitoring or measuring devices to enable monitoring of abstractions, storage and use of water by existing lawful users and establish links with any monitoring or management system as well as keep records of the water used.”

Therefore, to facilitate monitoring and informed management of a borehole, it is highly recommended that boreholes be equipped with the following monitoring infrastructure and equipment (diagram included in **Appendix D**):

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m.
- Installation of an electronic water level logger (for automated water level monitoring).
- Installation of a sampling tap (to monitor water quality).
- Installation of a flow volume meter (to monitor abstraction rates and volumes).

This monitoring data should be analysed by a qualified Hydrogeologist to ensure long-term sustainable use of the borehole. Legal compliance with regard to the use of groundwater also needs to be addressed with the Department of Water and Sanitation.

5. REFERENCES

- Barker, J.A., (1988) A Generalised Radial Flow Model for Hydraulic Tests in Fractured Rock. Water Resources Research, Vol. 24, No. 10 Pages 1796 – 1804.
- Council for Geoscience, 2019. 1:50 000 Geological series. 3418 BB Somerset West & 3418BD Hangklip.
- DWAF (1998). Quality of domestic water supplies, Volume 1: Assessment guide. Department of Water Affairs and Forestry, Department of Health, Water Research Commission, 1998.
- Meier, P.M., Carrera, J. & Sanchez-Vila, X (1998). An evaluation of Jacob’s method for the interpretation of pumping tests in heterogeneous formations. Water Resources Research, Vol. 34, No. 5. 1011 – 1025.
- SANS (10299-4:2003). South African National Standard. Development, maintenance and management of groundwater resources. Part 4: Test-pumping of water boreholes. ISBN 0-626-14912-6.
- SANS (241-1:2015). Drinking water – Part 1: Microbiological, physical, aesthetic and chemical determinants.

6. APPENDIX A: ESTIMATED BOREHOLE LOG


Log of Borehole No.: HP_BH3			
Location:	Lwandwe	Latitude:	-34.118704
Date:	22/06/2023	Longitude:	18.884398
Client:	GNEC	Ground Elevation:	57 mamsl
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Expected: Alluvium			160 mm (ID) Steel casing (0 mbgl - 41.71 mbgl) Water level (21.46 mbgl) Water Strike (42.46 mbgl & 44.56 mbgl) Open hole (41.71 mbgl - 112.26 mbgl) EOH (112.26 mbgl)
Drilled By:	Unknown	Remarks:	None of the estimated information included here is collected from the drilling records, but comes from the published 1:50 000 Geological Map of the area and measurements made during testing and camera logging
Drill Method:	Unknown		
Logged By:	Not logged, estimated from available data		

Log of Borehole No.: HP_BH4			
Location:	Lwandwe	Latitude:	-34.119343
Date:	22/06/2023	Longitude:	18.884644
Client:	GNEC	Ground Elevation:	53 mamsl
Lithological Description	Lithology Symbol & Depth (m)	Borehole Construction	Description & water strike
Unknown Geology Expected: Alluvium			110 mm (ID) uPVC casing (0 mbgl - 33.65 mbgl) (no slots observed) Water level (19.04 mbgl) EOH (33.65 mbgl)
Drilled By: Drill Method: Logged By:	Unknown Unknown Not logged, estimated from available data	Remarks:	None of the estimated information included here is collected from the drilling records, but comes from the published 1:50 000 Geological Map of the area and measurements made during testing and camera logging


7. APPENDIX B: CAMERA LOGGING

HP_BH3 Camera Logging – 30 May 2023

 2023/06/20 10:04:51	The water level at the time of the camera log was 21.46 mbgl
 2023/06/20 10:06:47	The end of the borehole casing was observed at 41.71 mbgl
 2023/06/20 10:07:49	A fracture was observed at 42.46 mbgl

	A fracture was observed at 44.56 mbgl
	No deeper fractures could be observed in the borehole, however; based on the yield testing results, it is evident that deeper fractures exist. The end of the borehole was measures at 112.26 mbgl.

HP_BH4 Camera Logging – 30 May 2023

 2023/06/20 09:41:14	The water level at the time of the camera log was 19.04 mbgl
 2023/06/20 09:42:35	uPVC casing joint appears to be in a good condition. Casing slots could not be observed in the borehole.
 2023/06/20 09:43:43	The end of the borehole was measures at 33.65 mbgl

8. APPENDIX C: YIELD TEST DATA

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
SPM	Strokes per minute
SWL	Static water level
u/c	Meters per coordinate

BOREHOLE TEST RECORD

ATS

CONSULTANT: GEOSS
 DISTRICT: SOMERSET WEST
 PROVINCE: WESTERN CAPE
 FARM / VILLAGE NAME: RHINO HPC
 DATE TESTED: 30-05-2023

PROJECT #	P2815
TEAM MEMBERS	

BOREHOLE LOCATION & ACCESS INFORMATION:		
BOREHOLE COORDINATES		COMMENTS ON ACCESS IF ANY:
LATITUDE (SOUTH):	S34 07 07.2	
LONGITUDE (EAST):	E18 53 04.0	
BOREHOLE NO:	BH03	
TRANSMISSIVITY VALUE:		
TYPE INSTALLATION:	NEW BOREHOLE	
BOREHOLE DEPTH: (mbgl)	114.2	

MAINTENANCE RECORD:		REHABILITATION RECORD:		DIGITAL CAMERA LOGGING:		EQUIPMENT FISHING RECORD	
Labour hours:		Jetting hours:		Camera logged once:		Hours spent:	
Cost of material:		Brushing hours:		Camera logged twice:		OTHER COSTS ON PROJECT:	
Travelling (km):		Airlifting hours:		Camera logged three times:			
		Sulphamic Acid KG's		Camera work sent to client:		Courier of samples:	
		Boresaver KG's				Km's for delivery:	
		Soda Ash KG's				Cost of packaging:	
COMMENTS:				RECOMMENDATIONS / CORRECTIVE ACTIONS:			

SAMPLE INSTRUCTIONS :

Water sample taken	Yes	No	If consultant took sample, give name:		DATA CAPTURED BY:	AVN
Date sample taken	01-06-2023		If sample courier, to where:		DATA CHECKED BY:	AVN
Time sample taken	07H50					

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	114.04
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	21.81
CASING DETECTION:	NO	RUST	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	50
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ SIGNATURE: _____
 DESIGNATION: _____ DATE: _____

BOREHOLE TEST CONTROL SHEET							
Groundwater Solutions t/a AB PUMPS							
Borehole number:	BH03		Old / Alternative number:				
Contractor:	ATS		Supervisor:				
Operator:			Rig number & Type rig:				
EXISTING EQUIPMENT							
Type pump	Depth	Condition	Drive unit	Condition	Pump house	Condition	Remarks
TESTING EQUIPMENT							
Pump type	Depth installed (m)	Date & time (started)		Date & time (completed)			
BP16	99.20	30-05-2023 13H00		30-05-2023 20H10			
MULTI-RATE OR STEPTTEST DETAILS							
STEP	DURATION (MIN)	RECOVERY (MIN)		YIELD (L/S)		DRAWDOWN (m)	
1	60			0.23	l/s	8.93	
2	60			0.52	l/s	26.84	
3	40	210		1.03	l/s	76.73	
4					l/s		
5					l/s		
6					l/s		
7					l/s		
8					l/s		
Calibration:					l/s		
TOTAL:	160	210			l/s		
COMMENT:							
CONSTANT RATE DISCHARGE TEST							
Pump type	Depth installed (m)	Date & time (started)		Date & time (completed)			
BP16	99.20	31-05-2023 08H00		01-06-2023 12H00			
Yield l/s	Drawdown (m)	Duration (min)		Recovery (min)			
0.42	48.77	1440		240			
Total: (Multi-rate and Constant Discharge rate)		1600		450			
COMMENT:							
	Borehole number	Duration (min) CONSTANT		Drawdown (m)	Hand/logger	Distance (m)	
Observation Hole 1						0	
Observation Hole 2						0	
Observation Hole 3						0	
Observation Hole 4							
Observation Hole 5							
GENERAL							
ESTABLISHMENT	From:		To:				
Site Move	From project#		To #:	P2815	Travelling km:	26	
	Village	Borehole no	Village	Borehole no			
			RHINO HPC	BH03			
Maintenance:	Work time hr		Parts repaired/ replaced		Travelling km		
After test measurements	Water level	21.81	Borehole depth	114.04	Casing depth m	RUST	
Water level before installing test pump: (mbch)			21.49				
Depth before installing test pump:			114.20				
Testpump Installed	Once / Twice / More		Reason:				
Installed Testpump	<10 l/s / >10l/s		Reason:				
Was existing equipment re-installed:			No:	If not where was it left:			
GPS Unit number:							
EC Unit number:							
Remarks:							
Signed Contractor:				Signed Consultant:			

FORM 5 E STEPPED DISCHARGE TEST & RECOVERY																													
BOREHOLE TEST RECORD SHEET																													
PROJ NO : P2815			Coordinates: SOUTH: S34 07 07.2						PROVINCE: WESTERN CAPE																				
BOREHOLE NO: BH03			EAST: E18 53 04.0						DISTRICT: SOMERSET WEST																				
ALT BH NO: 0									SITE NAME: RHINO HPC																				
ALT BH NO: 0																													
BOREHOLE DEPTH (m): 114.20			DATUM LEVEL ABOVE CASING (m): 0.98						EXISTING PUMP: 0																				
WATER LEVEL (mbdl): 22.47			CASING HEIGHT: (magl): 0.00						CONTRACTOR: ATS																				
DEPTH OF PUMP (m): 99.20			DIAM PUMP INLET (mm): 170.00						PUMP TYPE: BP16																				
STEPPED DISCHARGE TEST & RECOVERY																													
DISCHARGE RATE 1					RPM 248					DISCHARGE RATE 2					RPM 318					DISCHARGE RATE 3					RPM 567				
DATE: 30-05-2023		TIME: 13H00				DATE: 30-05-2023		TIME: 14H00				DATE: 30-05-2023		TIME: 15H00															
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD												
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)												
1	0.70		1		1	9.16		1		1	27.37		1		1	72.23													
2	0.95		2		2	9.35	0.41	2		2	27.85		2		2	68.70													
3	1.14		3		3	9.80	0.52	3		3	29.06	0.75	3		3	66.21													
5	1.28		5		5	10.75		5		5	32.06		5		5	61.70													
7	1.43		7		7	12.04	0.54	7		7	36.25	1.03	7		7	54.78													
10	1.78	0.24	10		10	13.52	0.52	10		10	40.74		10		10	48.84													
15	2.05	0.22	15		15	15.41		15		15	47.32	1.15	15		15	40.14													
20	4.96		20		20	17.22	0.53	20		20	59.29	1.03	20		20	36.50													
30	7.44	0.25	30		30	20.72		30		30	68.71		30		30	23.89													
40	8.46	0.24	40		40	22.80	0.51	40		40	76.73		40		40	16.53													
50	8.74		50		50	25.23	0.52	50		50	76.73	0.55	50		50	9.48													
60	8.93	0.23	60		60	26.84		60		60	76.73	0.50	60		60	5.76													
70			70		70			70		70	76.73	0.48	70		70	3.44													
80			80		80			80		80			80		80	2.59													
90			90		90			90		90			90		90	1.88													
100			100		100			100		100			100		100	1.40													
110			110		110			110		110			110		110	1.03													
120			120		120			120		120			120		120	0.75													
pH			150		pH			150		pH			150		150	0.34													
TEMP	18.40	°C	180		TEMP	20.40	°C	180		TEMP		°C	180		180	0.06													
EC	2	µS/cm	210		EC	2	µS/cm	210		EC		µS/cm	210		210	0.00													
DISCHARGE RATE 4					RPM					DISCHARGE RATE 5					RPM					DISCHARGE RATE 6					RPM				
DATE:		TIME:				DATE:		TIME:				DATE:		TIME:															
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD												
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)												
1			1		1			1		1			1		1														
2			2		2			2		2			2		2														
3			3		3			3		3			3		3														
5			5		5			5		5			5		5														
7			7		7			7		7			7		7														
10			10		10			10		10			10		10														
15			15		15			15		15			15		15														
20			20		20			20		20			20		20														
30			30		30			30		30			30		30														
40			40		40			40		40			40		40														
50			50		50			50		50			50		50														
60			60		60			60		60			60		60														
70			70		70			70		70			70		70														
80			80		80			80		80			80		80														
90			90		90			90		90			90		90														
100			100		100			100		100			100		100														
110			110		110			110		110			110		110														
120			120		120			120		120			120		120														
pH			150		pH			150		pH			150		150														
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		180														
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		210														
			240					240					240		240														
			300					300					300		300														
			360					360					360		360														
S/W/L:(mbch) 21.49																													

FORM 5 F															
CONSTANT DISCHARGE TEST & RECOVERY															
BOREHOLE TEST RECORD SHEET															
PROJ NO :		P2815		Coordinates: SOUTH: S34 07 07.2				PROVINCE:		WESTERN CAPE					
BOREHOLE NO:		BH03		EAST: E18 53 04.0				DISTRICT:		SOMERSET WEST					
ALT BH NO:		0						SITE NAME:		RHINO HPC					
ALT BH NO:		0													
BOREHOLE DEPTH:		114.20		DATUM LEVEL ABOVE CASING (m):				0.98		EXISTING PUMP:		0			
WATER LEVEL (mbdl):		22.47		CASING HEIGHT: (magl):				0.00		CONTRACTOR:		ATS			
DEPTH OF PUMP (m):		99.20		DIAM PUMP INLET(mm):				170		PUMP TYPE:		BP16			
CONSTANT DISCHARGE TEST & RECOVERY															
TEST STARTED				TEST COMPLETED											
DATE:		31-05-2023		TIME:		08H00		DATE:				TIME:			
				OBSERVATION HOLE 1				OBSERVATION HOLE 2				OBSERVATION HOLE 3			
				NR:				NR:				NR:			
DISCHARGE BOREHOLE				Distance(m);				Distance(m);				Distance(m);			
TIME (MIN)	DRAW DOWN (M)	YIELD (L/S)	TIME MIN	RECOVERY (M)	TIME: (min)	Drawdown m	Recovery (m)	TIME: (min)	Drawdown (m)	Recovery	TIME: (min)	Drawdown (m)			
1	0.80		1	45.27	1			1			1				
2	1.79		2	41.42	2			2			2				
3	2.36		3	39.70	3			3			3				
5	3.96	0.34	5	35.84	5			5			5				
7	5.58		7	30.80	7			7			7				
10	7.33	0.43	10	27.66	10			10			10				
15	8.60		15	23.00	15			15			15				
20	9.28	0.40	20	19.27	20			20			20				
30	10.95		30	13.94	30			30			30				
40	12.53	0.42	40	10.02	40			40			40				
60	14.97		60	5.24	60			60			60				
90	18.60	0.41	90	2.59	90			90			90				
120	20.64	0.40	120	1.90	120			120			120				
150	23.92	0.43	150	1.49	150			150			150				
180	25.88	0.42	180	1.26	180			180			180				
210	28.54	0.40	210	1.12	210			210			210				
240	30.02	0.43	240	1.00	240			240			240				
300	33.83	0.44	300		300			300			300				
360	37.46	0.41	360		360			360			360				
420	40.73	0.40	420		420			420			420				
480	43.25	0.40	480		480			480			480				
540	44.51	0.43	540		540			540			540				
600	45.66	0.42	600		600			600			600				
720	46.56	0.40	720		720			720			720				
840	47.48	0.43	840		840			840			840				
960	47.53	0.40	960		960			960			960				
1080	47.74	0.45	1080		1080			1080			1080				
1200	47.93	0.44	1200		1200			1200			1200				
1320	48.27	0.42	1320		1320			1320			1320				
1440	48.77		1440		1440			1440			1440				
1560			1560		1560			1560			1560				
1680			1680		1680			1680			1680				
1800			1800		1800			1800			1800				
1920			1920		1920			1920			1920				
2040			2040		2040			2040			2040				
2160			2160		2160			2160			2160				
2280			2280		2280			2280			2280				
2400			2400		2400			2400			2400				
2520			2520		2520			2520			2520				
2640			2640		2640			2640			2640				
2760			2760		2760			2760			2760				
2880			2880		2880			2880			2880				
3000			3000		3000			3000			3000				
3120			3120		3120			3120			3120				
3240			3240		3240			3240			3240				
3360			3360		3360			3360			3360				
3480			3480		3480			3480			3480				
3600			3600		3600			3600			3600				
3720			3720		3720			3720			3720				
3840			3840		3840			3840			3840				
3960			3960		3960			3960			3960				
4080			4080		4080			4080			4080				
4200			4200		4200			4200			4200				
4320			4320		4320			4320			4320				
Total time pumped(min):				1440		W/L		W/L		W/L		W/L			
Average yield (l/s):				0.42											

Copyright subsists in this work. No part of this work may be reproduced in any form or by any means without the publisher's written permission. Any unauthorised reproduction of this work will constitute a copyright infringement and render the doer liable under both civil and criminal law.

Abbreviations	
EC	Electrical conductivity
mbgl	Meters below ground level
mbch	Meters below casing height
mbdl	Meters below datum level
magl	Meters above ground level
L/S	Litres per second
SPM	Stones per minute
SWL	Static water level
u/cem	Micrograms per centimeter

BOREHOLE TEST RECORD

ATS

CONSULTANT: GEOSS
 DISTRICT: SOMERSET WEST
 PROVINCE: WESTERN CAPE
 FARM / VILLAGE NAME: RHINO HPC
 DATE TESTED: 01-06-2023

PROJECT #	P2815
TEAM MEMBERS	

BOREHOLE LOCATION & ACCESS INFORMATION:		
BOREHOLE COORDINATES		COMMENTS ON ACCESS IF ANY:
LATITUDE (SOUTH):	S34.11935	
LONGITUDE (EAST):	E18.88464	
BOREHOLE NO:	BH04	
TRANSMISSIVITY VALUE:		
TYPE INSTALLATION:	NEW BOREHOLE	
BOREHOLE DEPTH: (mbgl)	36.15	

MAINTENANCE RECORD:		REHABILITATION RECORD:		DIGITAL CAMERA LOGGING:		EQUIPMENT FISHING RECORD	
Labour hours:		Jetting hours:		Camera logged once:		Hours spent:	
Cost of material:		Brushing hours:		Camera logged twice:		OTHER COSTS ON PROJECT:	
Travelling (km):		Airlifting hours:		Camera logged three times:			
		Sulphamic Acid KG's		Camera work sent to client:		Courier of samples:	
		Boresaver KG's				Km's for delivery:	
		Soda Ash KG's				Cost of packaging:	
COMMENTS:				RECOMMENDATIONS / CORRECTIVE ACTIONS:			

SAMPLE INSTRUCTIONS :					
Water sample taken	Yes	No	If consultant took sample, give name:		DATA CAPTURED BY: AVN
Date sample taken	03-06-2023		If sample courier, to where:		DATA CHECKED BY: AVN
Time sample taken	07H30				

DESCRIPTION:	UNIT	QTY		UNIT	QTY
STRAIGHTNESS TEST:	NO	0	BOREHOLE DEPTH AFTER TEST:	M	36.15
VERTICALLY TEST:	NO	0	BOREHOLE WATER LEVEL AFTER TEST: (mbch)	M	19.53
CASING DETECTION:	NO	1	SAND/GRAVEL/SILT PUMPED?	YES/NO	0
SUPPLIED NEW STEEL BOREHOLE COVER:	NO	0	DATA REPORTING AND RECORDING	NO	1
BOREHOLE MARKING	NO	0	SLUG TEST:	NO	0
SITE CLEANING & FINISHING	NO	1	LAYFLAT (M):	M	30
LOGGERS FOR WATERLEVEL MONITORING	NO	0	LOGGERS FOR pH AND EC:	NO	0

It is hereby acknowledged that upon leaving the site, all existing equipment is in an acceptable condition.

NAME: _____ SIGNATURE: _____
 DESIGNATION: _____ DATE: _____

BOREHOLE TEST CONTROL SHEET							
Groundwater Solutions t/a AB PUMPS							
Borehole number:		BH04		Old / Alternative number:			
Contractor:		ATS		Supervisor:			
Operator:				Rig number & Type rig:			
EXISTING EQUIPMENT							
Type pump	Depth	Condition	Drive unit	Condition	Pump house	Condition	Remarks
TESTING EQUIPMENT							
Pump type	Depth installed (m)	Date & time (started)	Date & time (completed)				
Submersible	33.00	01-06-2023 15H05					
MULTI-RATE OR STEPTTEST DETAILS							
STEP	DURATION (MIN)	RECOVERY (MIN)	YIELD (L/S)		DRAWDOWN (m)		
1	60		0.26	l/s	0.03		
2	60		0.56	l/s	0.11		
3	120	5	0.90	l/s	0.20		
4				l/s			
5				l/s			
6				l/s			
7				l/s			
8				l/s			
Calibration:				l/s			
TOTAL:	240	5		l/s			
COMMENT:							
CONSTANT RATE DISCHARGE TEST							
Pump type	Depth installed (m)	Date & time (started)	Date & time (completed)				
Submersible	33.00	02-06-2023 08H02	03-06-2023 08H30				
Yield l/s	Drawdown (m)	Duration (min)	Recovery (min)				
0.86	0.29	1440	30				
Total: (Multi-rate and Constant Discharge rate)		1680	35				
COMMENT:							
	Borehole number	Duration (min) CONSTANT	Drawdown (m)	Hand/logger	Distance (m)		
Observation Hole 1					0		
Observation Hole 2					0		
Observation Hole 3					0		
Observation Hole 4							
Observation Hole 5							
GENERAL							
ESTABLISHMENT	From:	To:					
Site Move	From project#		To #:	P2815	Travelling km:	0.74	
	Village	Borehole no	Village	Borehole no			
			RHINO HPC	BH04			
Maintenance:	Work time hr		Parts repaired/ replaced		Travelling km		
After test measurements	Water level	19.53	Borehole depth	36.15	Casing depth m	UPVC	
Water level before installing test pump: (mbch)			19.51				
Depth before installing test pump:			36.15				
Testpump Installed	Once / Twice / More		Reason:				
Installed Testpump	<10 l/s / >10l/s		Reason:				
Was existing equipment re-installed:			No:	If not where was it left:			
GPS Unit number:							
EC Unit number:							
Remarks:							
Signed Contractor:				Signed Consultant:			

FORM 5 E																								
STEPPED DISCHARGE TEST & RECOVERY																								
BOREHOLE TEST RECORD SHEET																								
PROJ NO :		P2815		Coordinates: SOUTH: S34.11935					PROVINCE: WESTERN CAPE															
BOREHOLE NO:		BH04		EAST: E18.88464					DISTRICT: SOMERSET WEST															
ALT BH NO:		0							SITE NAME: RHINO HPC															
ALT BH NO:		0																						
BOREHOLE DEPTH (m)				36.15				DATUM LEVEL ABOVE CASING (m):				1.93			EXISTING PUMP: 0									
WATER LEVEL (mbdl):				21.38				CASING HEIGHT: (magl):				MAIN BOREH			CONTRACTOR: ATS									
DEPTH OF PUMP (m):				33.00				DIAM PUMP INLET (mm):				127.00			PUMP TYPE: Submersible									
STEPPED DISCHARGE TEST & RECOVERY																								
DISCHARGE RATE 1					RPM		DISCHARGE RATE 2					RPM		DISCHARGE RATE 3			RPM							
DATE:		01-06-2023		TIME:		15H05		DATE:		01-06-2023		TIME:		16H05		DATE:		01-06-2023		TIME:		17H05		
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)
1	0.03		1		1	0.05	0.48	1		1	0.13		1		1	0.08		1		1	0.13		1	0.08
2	0.03		2		2	0.05		2		2	0.14	0.90	2		2	0.14		2		2	0.14	0.90	2	0.03
3	0.04	0.23	3		3	0.07	0.56	3		3	0.14		3		3	0.14		3		3	0.14		3	0.01
5	0.03		5		5	0.07		5		5	0.15	0.92	5		5	0.15	0.92	5		5	0.15	0.92	5	0.00
7	0.03	0.22	7		7	0.06	0.55	7		7	0.16	0.89	7		7	0.16	0.89	7		7	0.16	0.89	7	
10	0.03		10		10	0.06	0.55	10		10	0.16		10		10	0.16		10		10	0.16		10	
15	0.04	0.21	15		15	0.07		15		15	0.17	0.90	15		15	0.17	0.90	15		15	0.17	0.90	15	
20	0.03		20		20	0.07	0.52	20		20	0.17		20		20	0.17		20		20	0.17		20	
30	0.03	0.20	30		30	0.08		30		30	0.17	0.90	30		30	0.17	0.90	30		30	0.17	0.90	30	
40	0.03		40		40	0.08	0.54	40		40	0.18	0.91	40		40	0.18	0.91	40		40	0.18	0.91	40	
50	0.03	0.20	50		50	0.10	0.56	50		50	0.18		50		50	0.18		50		50	0.18		50	
60	0.03		60		60	0.11		60		60	0.18	0.92	60		60	0.18	0.92	60		60	0.18	0.92	60	
70			70		70			70		70	0.19	0.89	70		70	0.19	0.89	70		70	0.19	0.89	70	
80			80		80			80		80	0.19	0.90	80		80	0.19	0.90	80		80	0.19	0.90	80	
90			90		90			90		90	0.18	0.88	90		90	0.18	0.88	90		90	0.18	0.88	90	
100			100		100			100		100	0.19	0.91	100		100	0.19	0.91	100		100	0.19	0.91	100	
110			110		110			110		110	0.20	0.90	110		110	0.20	0.90	110		110	0.20	0.90	110	
120			120		120			120		120	0.20		120		120	0.20		120		120	0.20		120	
pH			150		pH			150		pH			150		pH			150		pH			150	
TEMP	19.00	°C	180		TEMP	21.70	°C	180		TEMP	24.80	°C	180		TEMP	24.80	°C	180		TEMP	24.80	°C	180	
EC	2250	µS/cm	210		EC	1984	µS/cm	210		EC	1935	µS/cm	210		EC	1935	µS/cm	210		EC	1935	µS/cm	210	
DISCHARGE RATE 4					RPM		DISCHARGE RATE 5					RPM		DISCHARGE RATE 6			RPM							
DATE:				TIME:				DATE:				TIME:				DATE:				TIME:				
TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY	TIME	DRAW	YIELD	TIME	RECOVERY
(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)	(MIN)	DOWN (M)	(L/S)	(MIN)	(M)
1			1		1			1		1			1		1			1		1			1	
2			2		2			2		2			2		2			2		2			2	
3			3		3			3		3			3		3			3		3			3	
5			5		5			5		5			5		5			5		5			5	
7			7		7			7		7			7		7			7		7			7	
10			10		10			10		10			10		10			10		10			10	
15			15		15			15		15			15		15			15		15			15	
20			20		20			20		20			20		20			20		20			20	
30			30		30			30		30			30		30			30		30			30	
40			40		40			40		40			40		40			40		40			40	
50			50		50			50		50			50		50			50		50			50	
60			60		60			60		60			60		60			60		60			60	
70			70		70			70		70			70		70			70		70			70	
80			80		80			80		80			80		80			80		80			80	
90			90		90			90		90			90		90			90		90			90	
100			100		100			100		100			100		100			100		100			100	
110			110		110			110		110			110		110			110		110			110	
120			120		120			120		120			120		120			120		120			120	
pH			150		pH			150		pH			150		pH			150		pH			150	
TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		TEMP		°C	180		TEMP		°C	180	
EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210		EC		µS/cm	210	
			240					240					240					240					240	
			300					300					300					300					300	
			360					360					360					360					360	
S/W/L:(mbch)					19.51																			

FORM 5 F

CONSTANT DISCHARGE TEST & RECOVERY

BOREHOLE TEST RECORD SHEET

PROJ NO :	P2815	Coordinates: SOUTH: S34.11935		PROVINCE:	WESTERN CAPE
BOREHOLE NO:	BH04	EAST: E18.88464		DISTRICT:	SOMERSET WEST
ALT BH NO:	0			SITE NAME:	RHINO HPC
ALT BH NO:	0				
BOREHOLE DEPTH:	36.15	DATUM LEVEL ABOVE CASING (m):	1.93	EXISTING PUMP:	0
WATER LEVEL (mbdl):	21.38	CASING HEIGHT: (magl):	MAIN BOP	CONTRACTOR:	ATS
DEPTH OF PUMP (m):	33.00	DIAM PUMP INLET(mm):	127	PUMP TYPE:	Submersible

CONSTANT DISCHARGE TEST & RECOVERY

TEST STARTED					TEST COMPLETED									
DATE:	02-06-2023	TIME:	08H00		DATE:		TIME:			TYPE OF PUMP:			Submersible	
					OBSERVATION HOLE 1			OBSERVATION HOLE 2			OBSERVATION HOLE 3			
					NR:			NR:			NR:			
DISCHARGE BOREHOLE					Distance(m);			Distance(m);			Distance(m);			
TIME	DRAW	YIELD	TIME	RECOVERY	TIME:	Drawdown	Recovery	TIME:	Drawdown	Recovery	TIME:	Drawdown	Recovery	
(MIN)	DOWN (M)	(L/S)	MIN	(M)	(min)	m	(m)	(min)	(m)		(min)	(m)		
1	0.02		1	0.19	1			1			1			
2	0.04	0.85	2	0.10	2			2			2			
3	0.04		3	0.08	3			3			3			
5	0.05	0.86	5	0.05	5			5			5			
7	0.05		7	0.04	7			7			7			
10	0.05	0.85	10	0.03	10			10			10			
15	0.06		15	0.02	15			15			15			
20	0.06	0.80	20	0.01	20			20			20			
30	0.07		30	0.00	30			30			30			
40	0.08	0.86	40		40			40			40			
60	0.09	0.87	60		60			60			60			
90	0.09	0.86	90		90			90			90			
120	0.10		120		120			120			120			
150	0.11	0.85	150		150			150			150			
180	0.12		180		180			180			180			
210	0.13	0.85	210		210			210			210			
240	0.13	0.86	240		240			240			240			
300	0.14		300		300			300			300			
360	0.15	0.85	360		360			360			360			
420	0.16		420		420			420			420			
480	0.17	0.85	480		480			480			480			
540	0.18		540		540			540			540			
600	0.19	0.86	600		600			600			600			
720	0.21	0.87	720		720			720			720			
840	0.22		840		840			840			840			
960	0.24	0.87	960		960			960			960			
1080	0.24	0.85	1080		1080			1080			1080			
1200	0.26	0.87	1200		1200			1200			1200			
1320	0.27	0.86	1320		1320			1320			1320			
1440	0.29		1440		1440			1440			1440			
1560			1560		1560			1560			1560			
1680			1680		1680			1680			1680			
1800			1800		1800			1800			1800			
1920			1920		1920			1920			1920			
2040			2040		2040			2040			2040			
2160			2160		2160			2160			2160			
2280			2280		2280			2280			2280			
2400			2400		2400			2400			2400			
2520			2520		2520			2520			2520			
2640			2640		2640			2640			2640			
2760			2760		2760			2760			2760			
2880			2880		2880			2880			2880			
3000			3000		3000			3000			3000			
3120			3120		3120			3120			3120			
3240			3240		3240			3240			3240			
3360			3360		3360			3360			3360			
3480			3480		3480			3480			3480			
3600			3600		3600			3600			3600			
3720			3720		3720			3720			3720			
3840			3840		3840			3840			3840			
3960			3960		3960			3960			3960			
4080			4080		4080			4080			4080			
4200			4200		4200			4200			4200			
4320			4320		4320			4320			4320			
Total time pumped(min):				1440		W/L			W/L			W/L		
Average yield (l/s):				0.86										

9. APPENDIX D: WATER QUALITY



TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-08



@VinlabSA

Sample Details									
SampleID					W38911				
Water Type					Drinking Water				
Water Source					Borehole				
Sample Temperature									
Description					4450PhG_HP_BH3				
Batch Number					4450PhG_HP_BH3				
PO Number					4450PhG				
Date Received					2023-06-06				
Condition					Good				
Water - Routine									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
pH@25C (Water)		VIN-05-MW01	^^^	>= 5 to <= 9.7	6.71				
Conductivity@25C (Water)	mS/m	VIN-05-MW02	^	<= 170	181.6				
Turbidity (Water)*	ntu			<= 5	125				
Total dissolved solids (Water)*	mg/L			<= 1200	1231.25				
Free Chlorine (Water)*	mg/L			<= 5	<0.02				
Ammonia (NH4) as N (Water)	mg/L	VIN-05-MW08	2.5%	<= 1.5	<0.15				
Nitrate as N (Water)	mg/L	VIN-05-MW08	10%	<= 11	<1.00				
Nitrite as N (Water)	mg/L	VIN-05-MW08	10%	<= 0.9	<0.05				
Chloride (Cl-) - Water	mg/L	VIN-05-MW08	2.73%	<= 300	503.21				
Sulphates (SO4) - Water	mg/L	VIN-05-MW08	7.56%	<= 500	30.33				
Fluoride (F) - Water	mg/L	VIN-05-MW08	9.74%	<= 1.5	3.50				
Alkalinity as CaCO3 (Water)*	mg/L				78.80				
Colour (Water)*	mg/L Pt-Co			<= 15	21				
Total Organic Carbon (Water)*	mg/L			<=10	1.30				
Date Tested					2023-06-06				
Water - Metals									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
Calcium (Ca) - Water	mg/L	VIN-05-MW43	14.60%		43				

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer; W=winescan; A=atcolyzer; W = Winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/inactive in the wine. Some microbes, especially lactic acid, may not grow in culture even where viable/potentially active in the wine.

* - Conductivity <1000mS/m = ±1mS/m, >1000mS/m = ±9mS/m
 ** - CO₂, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
 *** - pH ±0.1

Doc No
V43529

VIN 09-01 30-11-2022

Page: 1 of 3

Visit Vinlab H2O





TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-08



@VinlabSA

Magnesium (Mg) - Water	mg/L	VIN-05-MW43	8.49%		33				
Sodium (Na) - Water	mg/L	VIN-05-MW43	11.45%	<= 200	259				
Potassium (K) - Water	mg/L	VIN-05-MW43	9.42%		7				
Zinc (Zn) - Water	mg/L	VIN-05-MW43	19.40%	<= 5	0.116				
Antimony (Sb) - Water*	µg/L			<= 20	<13.0				
Arsenic (As) - Water*	µg/L			<= 10	<10.0				
Boron (B) - Water	µg/L	VIN-05-MW43	11.79%	<= 2400	156				
Cadmium (Cd) - Water	µg/L	VIN-05-MW43	12.26%	<= 3	3				
Chromium (Cr) - Water	µg/L	VIN-05-MW43	13.03%	<= 50	6				
Copper (Cu) - Water	µg/L	VIN-05-MW43	11.57%	<= 2000	2				
Iron (Fe) - Water	µg/L	VIN-05-MW43	12.49%	<= 2000	11885				
Lead (Pb) - Water	µg/L	VIN-05-MW43	16.32%	<= 10	<8				
Manganese (Mn) - Water	µg/L	VIN-05-MW43	12.44%	<= 400	510				
Nickel (Ni) - Water	µg/L	VIN-05-MW43	17.38%	<= 70	<8				
Selenium (Se) - Water*	µg/L			<= 40	<10.0				
Aluminium (Al) - Water	µg/L	VIN-05-MW43	13.49%	<= 300	416				
Cyanide (CN) - Water*	µg/L			<= 200	<10.0				
Mercury (Hg) - Water*	µg/L			<= 6	<1.0				
Barium (Ba) - Water	µg/L	VIN-05-MW43	14.09%	<= 700	33				
Uranium (U) - Water*	µg/L			<= 30	<28				
Date Tested					2023-06-07				

Water - Micro

	Unit	Method	Uncertainty	Limits	Results	Results	Results	Results	Results
Total Coliforms (Water)	cfu/100mL	VIN-05-MW09		<= 10	nd				
E-Coli (Water)	cfu/100mL	VIN-05-MW09		not detected	nd				
Heterotrophic plate count*	cfu/mL			<= 1000	nd				
Date Tested					2023-06-06				

Comments

W38911
Two Samples received,
Ion balance = 0.4%

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Pyrometry, Winescan, Alcolyzer, Winescan. Micro results: Enumeration of yeast: WL, nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO₂ additions less than 10 days may depress the growth of microbes in culture although they are viable/inactive in the wine. Some microbes, especially lactic acid bacteria, may not grow in culture even where viable/potentially active in the wine.

^ - Conductivity <1000mS/m = ±1mS/m, >1000mS/m = ±9mS/m
^^ - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
*** - pH ±0.1

Doc No
V43529

VIN 09-01 30-11-2022

Page: 2 of 3

Visit Vinlab H2O



T0885



TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-08



@VinlabSA

Adelize

Adelize Fourie
Laboratory Manager (Waterlab)
VIN-05-
M01, M02, M03, M04, M05, M08, M10, M28,
M43, MW01, MW02, MW03, MW04,
MW05, MW06, MW07, MW08/S10,
MW12, MW13, MW14

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py: pycnometer, W: winescan, A: alcoholyzer, W: winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

^A - Conductivity <1000µmS/m = ±1mS/m, >1000µmS/m = ±9mS/m
^{AA} - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
^{AAA} - pH ±0.1

Doc No
V43529

VIN 09-01 30-11-2022

Page: 3 of 3

Visit Vinlab H2O





TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling
P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-12



@VinlabSA

Sample Details									
SampleID					W38912				
Water Type					Drinking Water				
Water Source									
Sample Temperature									
Description					4450PhG_HP_BH4				
Batch Number					4450PhG_HP_BH4				
PO Number					4450PhG				
Date Received					2023-06-06				
Condition					Good				
Water - Routine									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
pH@25C (Water)		VIN-05-MW01	^^^	>= 5 to <= 9.7	5.97				
Conductivity@25C (Water)	mS/m	VIN-05-MW02	^	<= 170	208				
Turbidity (Water)*	ntu			<= 5	1.58				
Total dissolved solids (Water)*	mg/L			<= 1200	1410.24				
Free Chlorine (Water)*	mg/L			<= 5	<0.02				
Ammonia (NH4) as N (Water)	mg/L	VIN-05-MW08	2.5%	<= 1.5	<0.15				
Nitrate as N (Water)	mg/L	VIN-05-MW08	10%	<= 11	2.46				
Nitrite as N (Water)	mg/L	VIN-05-MW08	10%	<= 0.9	<0.05				
Chloride (Cl-) - Water	mg/L	VIN-05-MW08	2.73%	<= 300	589.93				
Sulphates (SO4) - Water	mg/L	VIN-05-MW08	7.56%	<= 500	61.43				
Fluoride (F) - Water	mg/L	VIN-05-MW08	9.74%	<= 1.5	0.36				
Alkalinity as CaCO3 (Water)*	mg/L				38.10				
Colour (Water)*	mg/L Pt-Co			<= 15	<15				
Total Organic Carbon (Water)*	mg/L			<=10	1.35				
Date Tested					2023-06-06				
Water - Metals									
	Unit	Method	Uncertainty	Limit	Results	Results	Results	Results	Results
Calcium (Ca) - Water	mg/L	VIN-05-MW43	14.60%		30				

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer; W=winescan; N=alcolyzer; W=Winescan. Micro results: Enumeration of yeast: YL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/inactive in the wine. Some microbes, especially lactic acid bacteria, may not grow in culture even where viable/potentially active in the wine.

^ - Conductivity <1000mS/m = ±1mS/m, >1000mS/m = ±9mS/m
^^ - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
^^^ - pH ±0.1

Doc No
V43549

VIN 09-01 30-11-2022

Page: 1 of 3

Visit Vinlab H2O



T0885



TEST REPORT

Water

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-12



@VinlabSA

Magnesium (Mg) - Water	mg/L	VIN-05-MW43	8.49%		66				
Sodium (Na) - Water	mg/L	VIN-05-MW43	11.45%	<= 200	255				
Potassium (K) - Water	mg/L	VIN-05-MW43	9.42%		7				
Zinc (Zn) - Water	mg/L	VIN-05-MW43	19.40%	<= 5	0.009				
Antimony (Sb) - Water*	µg/L			<= 20	<13.0				
Arsenic (As) - Water*	µg/L			<= 10	<10.0				
Boron (B) - Water	µg/L	VIN-05-MW43	11.79%	<= 2400	44				
Cadmium (Cd) - Water	µg/L	VIN-05-MW43	12.26%	<= 3	2				
Chromium (Cr) - Water	µg/L	VIN-05-MW43	13.03%	<= 50	4				
Copper (Cu) - Water	µg/L	VIN-05-MW43	11.57%	<= 2000	4				
Iron (Fe) - Water	µg/L	VIN-05-MW43	12.49%	<= 2000	52				
Lead (Pb) - Water	µg/L	VIN-05-MW43	16.32%	<= 10	<8				
Manganese (Mn) - Water	µg/L	VIN-05-MW43	12.44%	<= 400	12				
Nickel (Ni) - Water	µg/L	VIN-05-MW43	17.38%	<= 70	<8				
Selenium (Se) - Water*	µg/L			<= 40	<10.0				
Aluminium (Al) - Water	µg/L	VIN-05-MW43	13.49%	<= 300	70				
Cyanide (CN) - Water*	µg/L			<= 200	<10.0				
Mercury (Hg) - Water*	µg/L			<= 6	<1.0				
Barium (Ba) - Water	µg/L	VIN-05-MW43	14.09%	<= 700	81				
Uranium (U) - Water*	µg/L			<= 30	<28				
Date Tested					2023-06-07				

Water - Micro

	Unit	Method	Uncertainty	Limits	Results	Results	Results	Results	Results
Total Coliforms (Water)	cfu/100mL	VIN-05-MW09		<= 10	3				
E-Coli (Water)	cfu/100mL	VIN-05-MW09		not detected	1				
Heterotrophic plate count*	cfu/mL			<= 1000	400				
Date Tested					2023-06-06				

Comments

W38912
Two Samples received,
Ion balance = 1.4%

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer, W=winescan, A=alcolyzer, W=winescan. Micro results: Enumeration of yeast: WL, nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/lactative in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

^ - Conductivity <1000µS/m = ±1mS/m, >1000µS/m = ±9mS/m
^^ - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
*** - pH ± 0.1

Doc No
V43549

VIN 09-01 30-11-2022

Page: 2 of 3

Visit Vinlab H2O



T0885



TEST REPORT

Water

Distillery Road
Stellenbosch
Tel 021-8828866/7
info@vinlab.com
www.vinlab.com
2023-06-12

Geoss South Africa (Pty) Ltd

Attn: Alison McDuling

P.O.Box 12412
Die Boord, Stellenbosch
7613
+27218801079



@VinlabSA

Adelize

Adelize Fourie
Laboratory Manager (Waterlab)

VIN-05-
M01,M02,M03,M04,M05,M08,M10,M28,
M43,MW01,MW02,MW03,MW04,
MW05,MW06,MW07,MW08/910,
MW12,MW13,MW14

Kalinke

Kalinke Rossouw
Laboratory Technician

VIN-05-M01,M02,M04,M05,M08,M10,
M28,M40,MW01,MW02,MW03,MW04,
MW08,MW09,MW10,MW12,MW13,MW14,
MW43,VIN-05-M42,M44,M45,M46,
M48,M49,M50,M51,M52,M53,M54,
M55

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab. Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer, W=winescan, A=alcolyser. W = Winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

Δ - Conductivity <1000mS/m = ±1mS/m, >1000mS/m = ±9mS/m
AA - COD, LR = ±18mg/L, MR = ±48mg/L, HR = ±477mg/L
AAA - pH ±0.1

Doc No
V43549


VIN 09-01 30-11-2022


Page: 3 of 3

Visit Vinlab H2O




10. APPENDIX E: MONITORING INFRASTRUCTURE DIAGRAM





11. APPENDIX F : YIELD TEST DATA ANALYSIS


HP_BH3




FC - Non Linear Method to estimate Q Sust

skin effect	Non-Darcian loss		Darcian loss		
A	C	p	B	n	e
0.00E+00	0.00E+00	2.00E+00	5.50E-02	1.00E+00	1.33E+00

Extrapolation	
Ext. pol. time (min)	1051200
Q (L/s)	0.2
Drawdown (m)	58.66




Available drawdown (m) =		48	
No boundaries	1 no-flow	2 no-flow	Closed
0.2	0.1	0.1	0.0
Q Sust (L/s)=	0.20	std.dev = 0.07	
Boundaries selected	0.00		




Cooper-Jacob method

T (m ² /d) =	1.6	r _a (m) =	0.1
S =	4.40E-10	Q (l/s) =	0.42
No boundaries	1 no-flow	2 no-flow	Closed
Q sust	0.34	0.17	0.11
Avg. Q sust =	0.18	std. dev =	0.11
Boundaries selected	0 - closed		




FC method

Extrapolation time in years	2	1051200	Extrapol. time in minutes
Effective borehole radius (r _e)	34.6906933	34.6906933	Est. r _e
Q (l/s) from pumping test	0.42	9.54322E-06	From r(e) sheet
s _a (available drawdown), sigma_s	48	0	Change r _e
Annual effective recharge (mm)	0	48.77	Sigma_s from risk
t(end) and s(end) of pumping test	1440	48.77	s _a available working draw n(m)
Average maximum derivative	5.14	43.21270295	End time and draw down n of test
Average second derivative	0.45	-0.12272914	Estimate of average of max deriv
Derivative at radial flow period	9.59827687	9.598276871	Estimate of average second deriv
T-early (m ² /d)	0.691864184	Aqui. thick (m)	60
T and S estimates	T-late [m ² /d]	1.291965759	Est. S-late
	S-late	0.0033	0.0033
BASIC SOLUTION			
No boundaries	1 no-flow	2 no-flow	Closed no-flow
sWell (Extrap. time) =	65.33	80.05	94.77
Q sust (l/s) =	0.31	0.25	0.21
Average Q sust (l/s) =	0.22	0.17	0.15
with standard deviation =	0.07		
Boundaries selected	0 - closed		



Barker method











	K _r [m/d]	S _p [1/m]	b	n	N
Fit Parameters	148.69	1.60E-07	0.03	1.89	0.0550
	No boundaries	1 no-flow	2 no-flow	Closed	
	sWell (Extrap. time)	76.62	106.06	120.77	135.49
	Q_sust	0.26	0.19	0.17	0.15
Fractal n = 1.89	Average Q-sust (l/s) =		0.19	std. dev =	0.05
	Boundaries selected		0 - closed		



Recovery

T (m ² /d)	1.6
CDT Duration	1440
Recovery Duration	240
Max % Recovery	97.9

HP_BH4



(LAST PAGE)